	nnn.		F .	Regulatory	i .	EPA	NPL.		NES
Name	PRP	State	Branch	Lead	Other Agencies	Region	count	RPM	NPL
Chemours/DuP ont Washington Works Plant	DuPont/Chemours	WV	WPD	EPA-WPD	WV Dept of Health/WV Dept. of Environmental Protection	3		Roger Reinhart	no
Harrisburg International Airport & United Water, Middletown	Airport	PA	WPD	PADEP	PA Dept of Health	3		Roger Reinhart	no
Doylestown Water Authority Public Water Supply Well		PA	WPD	PADEP	PA Dept of Health	3		Roger Reinhart	no
Former US Army Corps of Engineers Fire Training Center, Worchester	Army Corps of Engineers (suspected)	PA	WPD	PADEP	MCHD, township	3		Roger Reinhart	no
•	Unknown for ground water sources; surface intake likely former Willow Grove NAS	PA	WPD	PADEP		3		Roger Reinhart	no
North Penn Water Authority East Rockhill Public Water System		PA	WPD	PADEP	BCHD, East Rockhill Twp, West Rockhill Twp, Perkasie Borough	3		Roger Reinhart	no
Martinsburg Water Authority	Air Guard	WV	WPD	WVDHHR	WVDEP	3		Kevin Rowsey	no

Admin Vehicle	PFAS release	Above 70ppt (additive)	On-property Sampling	Off-property Sampling	Delineation Complete	On-property exposure (current human)
SDWA	confirme					
Order	d	yes	yes	yes	no	yes
State HSCA						
and State SDWA			yes	yes	no	yes
30111	u	yes	yes	ye3	110	yes
	confirme					
State HSCA		yes	yes	yes	no	yes
	confirme					
State HSCA	d	yes	yes	yes	no	no
	confirme					
NA	d	no	yes	yes	NA	NA
State	confirme					
SDWA	d	yes	yes	yes	no	yes
State clean	confirme					
up			yes	no	no	yes

Off-property exposure (current human)	Eco exposure	Drinking water affected	Past Activities
yes	yes	Yes	EPA Regions 3 & 5 issued an emergency order under the Safe Drinking Water Act and revised it once to include the goal of treating water supplies to below the lifetime health advisory.
yes	unknown	Yes	United Water System and Airport sampled under UCMR.
yes	unknown	Yes	Public water supply well sampled under UCMR. No known contamination source. Site is one mile from a local, small airport. PADEP sampled about 250 private wells nearby. Five properties receiving bottled water and 2 got carbon filters.
unknown	unknown	Yes - unused well	Former Nike missile site later used by the Army Corps of Engineers for fire fighting training. Site is inactive and unoccupied. Township sampled on-site wells. Former base drinking water well has PFOS/PFOA levels above the health advisory.
NA	NA	no	Aqua PA had below-HA detections in 18 of 20 Bucks and Montgomery Co wells. Detections may be associated with Willow Grove.
yes	unknown		North Penn independently sampled the two East Rockhill wells. One exceeded the health advisory level with 117 ppt of combined PFOS+PFOA. The sample from other well contained 65 ppt combined PFOA+PFOS and is still in-service. 125 homes sampled.
yes	unknown		1 well exceeded (Big Springs Well). Also sampled sampled private wells to identify extents of PFOS and possible source.

		Future	Media	
Exposure addressed	On-going or planned activities	Implications		Last update
Chemours has provided alternate				
water where necessary. Sampling is				
ongoing. Private wells receive GAC	EPA and state now looking into			
treatment or are hooked up to public	GenX releases and possible			
supply if possible. Chemours	contamination in drinking water			
maintains the GAC systems and tests	supplies. And PFOA/PFOS			
the water quarterly.	sampling continues.		yes	29-Sep-17
United Water well taken offline at the				
Airport, system re-worked to enable				
continued operation without the well.				
Airport had 4 wells impacted,				
installing treatment under DEP				
permits.			no	29-Sep-17
W II I I I I I I I I I I I I I I I I I				
Well shut down in May 2016. 5	Garage Marchaelan all			
properties received bottled water. 2	Sampling. Monitoring well			05.0.47
properties received carbon filters.	installation will start soon.		no	05-Oct-17
	Off-site sampling in progress.			
	Sampling and characterization is			
	ongoing.		no	05-Oct-17
One Hatboro well (off line for 2 years)	Ungering.			05 000 17
had combined value of 99 ppt				
(9/16/16 retested at 63 ppt) and one				
well in the Chalfont area had 68 ppt				
combined PFOA/PFOS and was shut				
down. The Chalfont well was				
retested at 19 ppt and most recently				
at 40.2 ppt, r	Continued monitoring.		no	29-Sep-17
North Penn shut down the well with	· · · · · · · · · · · · · · · · · · ·			
the exceedance, is supplementing				
with purchased water from Perkasie				
Borough, was arranging to resample				
and was preparing to notify their				
customers of the findings. 5				
properties receiving bottled water	State is sampling nearby private			
and 1 has carbon fi	wells.		yes	05-Oct-17
Big Springs Well shut down and will	GAC will be installed. Discussions			
install GAC filter (currently out for	with ANG ongoing regarding			
bid).	possible source.		yes	06-Oct-17